AWTA Product Testing

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031 P.O Box 240, North Melbourne, Victoria 3051 Phone (03) 9371 2400

TEST REPORT

Client: Rojo Pacific Pty Ltd

PO Box 1207

Blackburn North VIC 3130

20-002117 Test Number :

Issue Date

28/04/2020

Print Date

28/04/2020

Sample Description

Clients Ref:

"ROLAM - LPF200"

Embossed film self adhere with release paper

AS 4586-2013 Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

27/04/2020 Date of Testing

Test Temperature (20±5degC) 22 °C

Sample Preparation Washed with pH neutral detergent and dried

Test Direction Length

Fixed/Unfixed Unfixed

Slider No 96 Batch No 87

2 3 5 SRV Length 1 4 British Pendulum 38 37 36 37 37 37

Number

Classification РЗ

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019 Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

201799 43883 Page 1 of 1

Australian Wool Testing Authority Ltd Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing - Chemical Testing

Mechanical Testing

Performance & Approvals Testing

: Accreditation No Accreditation No

983

· Accreditation No. 1356

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd

A. JACKSON B.Sc.(Hons)

APPROVED SIGNATORY